## POLICE



## DEPARTMENT

## No. H5-241656/2025/PHQ

Police Headquarters,
Thiruvananthapuram
Vazhuthacaud
Pincode:695010

□phq.pol@kerala.gov.in
□04712721547
Dated.01-12-2025

## **Quotation Notice No.9/2025/PHQ-LSGD Election-2025**

Sealed quotations are invited for purchasing of **One 3 KVA UPS as per the following specifications** for installing at the office of DySP Motor Transport Wing PHQ in connection with 'General Election to Local Self Government Institutions - 2025 '

UPS 3 KVA (42 Ah - 6 nos of Batteries)  Specifications:  3 KVA/72 VDC UPS with Online Double Conversion , High Frequency IGBT, DSP and Dual microprocessor controlled system, Capacity -3 KVA /72 V, Online UPS Nominal input voltage – 170 V-270 VAC, Single Phase Input Single Phase output and , Nominal Input frequency -50 HZ +/_ 1Hz, permissible input frequency variation +/-5%, Input power factor –0 .9, Input current Distortion – I-THD-<=5%, Nominal output voltage – 220/230 V AC Single phase, Output power factor=0.8 or higher ,Output voltage regulation- +/-1%, Nominal output frequency – 50 Hz, Output frequency tolerance +/-0.05%, Output crest factor capacity – 3:1, UPS efficiency - >85 % and above, Ventilation – Forced – Air cooled, LED/LCD Display for –Mains on, Inverter on, Battery Low, Over Load, Load Percentage, - Battery low Pre-alarm, Trip, Output short circuit protection, Output over/under voltage, Battery over temperature alarm with 06 Nos of 12V/42AH SMF Batteries with Battery Rack and accessories.  WARRANTY – UPS -2 YEAR, BATTERY - 2 YEARS, MANDATORY CERTIFICATION, BIS, ISO9001-2008, ISO 14001 2015 AND ONESAS 18001: 2007 and CE Contification	L.No	ltem	Quantity
output voltage – 220/230 V AC Single phase, Output power factor=0.8 or higher ,Output voltage regulation- +/-1%,, Nominal output frequency – 50 Hz, Output frequency tolerance +/-0.05%, Output crest factor capacity – 3:1, UPS efficiency - >85 % and above, Ventilation – Forced – Air cooled, LED/LCD Display for –Mains on, Inverter on, Battery Low, Over Load, Load Percentage, - Battery low Pre-alarm, Trip, Output short circuit protection, Output over/under voltage, Battery over temperature alarm with 06 Nos of 12V/42AH SMF Batteries with Battery Rack and accessories.  WARRANTY – UPS -2 YEAR, BATTERY - 2 YEARS, MANDATORY CERTIFICATION, BIS, ISO9001-2008, ISO	L.NO	UPS 3 KVA (42 Ah - 6 nos of Batteries)  Specifications:  3 KVA/72 VDC UPS with Online Double Conversion, High Frequency IGBT, DSP and Dual microprocessor controlled system, Capacity -3 KVA /72 V, Online UPS Nominal input voltage – 170 V-270 VAC, Single Phase Input Single Phase output and, Nominal Input frequency -50 HZ +/_ 1Hz, permissible input frequency variation +/-5%, Input power	
MANDATORY CERTIFICATION, BIS, ISO9001-2008, ISO	1	output voltage – 220/230 V AC Single phase, Output power factor=0.8 or higher ,Output voltage regulation- +/-1%,, Nominal output frequency – 50 Hz, Output frequency tolerance +/-0.05%, Output crest factor capacity – 3:1, UPS efficiency - >85 % and above, Ventilation – Forced – Air cooled, LED/LCD Display for –Mains on, Inverter on, Battery Low, Over Load, Load Percentage, - Battery low Pre-alarm, Trip, Output short circuit protection, Output over/under voltage, Battery over temperature alarm with 06 Nos of 12V/42AH SMF Batteries with Battery Rack and	
IEC 62040 -1,2 &3.		MANDATORY CERTIFICATION, BIS, ISO9001-2008, ISO 14001-2015 AND OHSAS 18001: 2007 and CE Certification,	

The quotation should contain the price of the items including tax and service charges. The quotation should be submitted in an envelope bearing "Quotation for One 03 KVA UPS" and addressed to the State Police Chief, Police Headquarters, Thiruvananthapuram. Intending suppliers may submit their quotation in their own letter head along with TIN/CST/GSTIN Number. Last date of receipt of quotation is on 03.12.2025 at 11 A.M due to election emergency requirement. Late Quotations will not be acceptable. Payment will be made only after verification of the supplied items and the service .Advance payment will not be allowed.

SUJIT HDAS S IPS Assistant Inspector General

For Director General of Police-cum-State
Police Chief

To : The Official website of Kerala Police

Copy To : SI Tele C& C Lab PHQ for information and necessary action



