

POLICE



DEPARTMENT

No. C2-879/2026/FSL

Forensic Science Laboratory,
Thiruvananthapuram
PHQ Compound,
Vazhuthacaud
Pincode:695010

✉dirfsl.pol@kerala.gov.in

☎04712721533

Dated. 21-02-2026

Quotation Notice

Quotation Number	39/25-26
Items	2 Nos of Air Conditioner
Due date and time for receipt of quotation	28/02/2026 12.00 NOON
Date, Place and Time of opening of quotation	28/02/2026 3.00 PM, Forensic Science Laboratory, Thiruvananthapuram
Designation and address of officer to whom the quotation is to be addressed	Director Forensic Science Laboratory, Thiruvananthapuram-695010

Sealed quotations are invited for the " Purchase of 2 Nos of Air Conditioner in Forensic Science Laboratory, Thiruvananthapuram". The envelopes containing the quotations should bear the superscription " Purchase of 2 Nos of Air Conditioner in Forensic Science Laboratory, Thiruvananthapuram" and should be addressed to the Director, Forensic Science Laboratory, Police Department, Thiruvananthapuram 695010, Kerala. The last date for the receipt of quotations is 28/02/2026 12.00 NOON. Late quotations will not be accepted. The quotations will be opened at Forensic Science Laboratory, Thiruvananthapuram on 28/02/2026 , 3.00 PM in the presence of such of the quotationer or their authorized representatives. The maximum period required for the delivery of the articles should be mentioned. Details of the requirements and the conditions governing their supply can be obtained free on request from the Director, Forensic Science Laboratory, Tvpm till 28/02/2026 12.00 NOON.




C2-879/2026/FSL



fbccOff

Specification

1. Split Inverter Type AC
2. Capacity: 1 Ton
3. Shall be with inverter technology with a minimum 5-star BEE rating
4. Copper tubing for both condenser and evaporator coils is required.
5. Designed for 230V, single-phase, 50Hz supply, with voltage fluctuation tolerance of
6. Outdoor units should be mounted on sturdy brackets or platforms, often with vibration isolation.
7. Variable speed (Inverter) compressor, remote control, and anti-rust coating for outdoor units.
8. Compliance with IS 1391-1 (Room Air Conditioners) and IS 8148 (Package AC).
9. Adherence to safety codes like IS 659.
10. The unit should have full function battery operated cordless remote control.
11. The indoor units shall be mounted at a suitable height.
12. The quotes shall include installation charges(Companies participating may visit the site to inspect the installation requirements.)
13. Should be Eco friendly(R-32 or R-410A eco-friendly refrigerants)



PRADEEP SAJI K
Director FSL

